

# PUBLIC NOTIFICATION

## Thomas Mackey Water Treatment Plant Municipal Customers

Baciff MUD	James Wistinghausen	bacliffmud@comcast.net	Mike Morgan	mike_bmud@outlook.com
Bayview MUD	Richard Evans	richard.evans@bayviewmud.com	Bayview MUD	bayviewmud@bayviewmud.com
City of Galveston	Dennis Stark	dstark@galveston.tx.gov		
City of Hitchcock	Marie Gellas	migelles@cityofhitchcock.org		
City of La Marque	Deek Shaver	d.shaver@cityoflamarque.org		
City of League City	Jody Hooks	jody.hooks@leaguecitytx.gov		
City of Texas City	Corbin Ballast	cballast@texascitytx.gov	Jason Baecker	jbaecker@texascitytx.gov
GC FWSD No 6 (Tiki Island)	Steve Jefferson	gcfwsd_6@yahoo.com		
GC MUD No 12 (Bayou Vista)	Richard Matthews	rmatthews6490@gmail.com		
GC WCID No 1 (Dickinson)	Russell Grubbs	rgrubbs@wcid1.com	Darrell Hartwick	dhartwick@wcid1.com
GC WCID No 8 (Santa Fe)	James Newman	waters65@comcast.net	Dee Ann Hedgpeth	growwcid@comcast.net
GC WCID No 12 (Kemah)	Johnny Bellamy	jbellamy@municipaldistrictservices.com		
San Leon MUD	Andrew Miller	amiller@slmud.org	San Leon MUD	slmud1@slmud.org

FROM: Gulf Coast Water Authority's Thomas Mackey Water Treatment Plant Superintendent - Tony Garcia

Office Phone: 409.797.4919

Cell Phone: 281.967.1917

Fax: 409.943.4522

Email: tgarcia@gcwater.org

### NOTICE OF COMPLIANCE for the TCEQ MONTHLY REPORT

Date: Monday July 6th, 2020

For the Month of: June 2020

Distribution List Updated March 12, 2019

## PUBLIC NOTIFICATION

### TREATMENT TECHNIQUE VIOLATIONS

if YES, date when notice was given to:  
COMMISSION CUSTOMERS

YES / NO

Were more than 5% of the turbidity readings above the acceptable level?	NO	
Were there any days with the turbidity readings above 1.0 NTU?	NO	
Were there any days with the turbidity readings above 5.0 NTU?	NO	
Were there any periods were the plant failed to meet the CT requirements for more than 4.0 consecutive hours?	NO	
Were there any periods when the residuals leaving the plant fell below the acceptable level for more than 4.0 consecutive hours?	NO	
Were more than 5% of the residuals in the distribution system below the acceptable level for two months in a row?	NO	